

**CITY OF BLYTHE  
PUBLIC WORKS DEPARTMENT**

**ENGEVIK PARK PLAYGROUND IMPROVEMENT PROJECT  
NW CORNER OF CARLTON AND W. BARNARD**

**ADDENDUM NO. 1  
BID OPENING: THURSDAY, SEPTEMBER 29, 2022 AT 2:00PM**

**Date: September 16, 2022  
To: All Prospective Bidders**

**ADDENDUM No. 1**

This addendum shall be considered part of the Plans, Specifications, and Contract Documents (except as noted otherwise) and is issued to change, amplify, or delete from or otherwise explain these documents where provisions of this addendum differ from those of the original documents. This addendum shall have precedence over the original documents and shall govern.

**1. *Is this a CDBG project like last time (Miller Park Playground Improvement project)?***

No, this is not a federally funded project like CDBG. However, the contractor will be required to provide certified payroll records for all workers subject to prevailing wage.

**2. *What is the allowance?***

The Force Account Allowance is 10%

**3. *Is the contractor required to obtain a permit from the City?***

No permits are required for this project.

**4. *Will the City provide project signage?***

The City will provide one project sign.

**5. *What is the budget?***

The "project budget" of \$110,000 outlined in the Specification's for the Project should be treated as the City's project estimate.

**6. *Can Class 2 base be used instead of concrete base?***

Yes.

7. ***The current square footage for the space is approximately 4,460sf and the area is 64 x 64 within the existing concrete curbing, but the bidding papers state the area to be bid is 2,875sf. What is the correct SF as well as the area in linear feet per side so we can order the playground structures in accordance with the Safety Zone Areas needed.***

The total project area is 64 x 64, for a total inside the existing concrete curb of 4,460sf. The 2,875sf was a reference to where the fall protection should be installed. The project area is 4,460sf. Please provide base and poured in place fall protection under the playground equipment. The area between play structures may be left with the existing sand.

8. ***What is the turndown area of 417lf of edges?***

This item was removed from the bid.

9. ***The City of Blythe will be doing all demo and excavation down to 7" below existing curb correct?***

Yes.

10. ***Please provide specific layout of new area for the new playground equipment.***

There is no specific layout. As long as all required elements are provided, they may be arranged within the project area however the contractor sees fit.

11. ***Will the poured in place be 50% standard color and 50% black with aromatic binder?***

Yes.


12. ***Do you want any drainage?***

No.

13. ***Please use the revised Bid Form "Engevik Park Playground Improvement Project Schedule, Quantities and Prices" provided with this Addendum.***

**END OF ADDENDUM NO. 1**

City of Blythe

  
Mallory Crecelius,  
Interim City Manager

Acknowledgement of Receipt  
Addendum No. 1

\_\_\_\_\_  
Signature of Bidder

## **2.SCHEDULE OF ITEMS AND PRICES**

In accordance with City's **INVITATION FOR PROPOSALS**, the undersigned BIDDER hereby proposes to furnish all materials, equipment, tools, labor and incidentals required for the above stated project as set forth in the Plans, Specifications and contract documents and any addenda, thereto, and to perform all work in the manner and time prescribed therein.

BIDDER understands that a bid is required for the entire work. It is agreed that the unit and/or lump sum prices bid include all appurtenant expenses, bonds, taxes, royalties, transportation and fees.

If awarded the Contract, the undersigned further agrees that in the event of the BIDDER'S default in executing the required contract and filing the necessary bonds and insurance certificates within ten working days after the date of the City's notice of award of contract to the BIDDER, the proceeds of the security accompanying this bid shall become the property of the City and this bid and the acceptance hereof may, at the City's option, be considered null and void.

In case of discrepancies in the amounts bid, unit prices shall govern over extended amounts, and the accurate and mathematically correct summation of the total bid item amounts shall govern over the total for comparison summation figure and words listed on the proposal form.

**ENGVIK PARK PLAYGROUND IMPROVEMENT PROJECT  
SCHEDULE, QUANTITIES AND PRICES**

<b>Bid Item</b>	<b>Description</b>	<b>Quantity</b>	<b>Unit of Measure</b>	<b>Unit Price</b>	<b>Total</b>
1	MOBILIZATION, LICENSES, CONSTRUCTION STAKING, TAXES, PERFORMANCE BOND, PAYMENT BOND, INSURANCE, POTABLE DRINKING WATER, CONSTRUCTION WATER, FREIGHT, UTILITY RELOCATIONS, TEMPORARY RESTROOM FACILITIES, SITE SECURITY, DEMOBILIZATION, CLEAN UP AND OTHER COSTS SPECIFICALLY ADDRESSED WITHIN THIS SCHEDULE OF ITEMS AND PRICES	1	LS	\$	\$
2	PROVIDE AND INSTALL 2,875 SF OF POURED IN PLACE SURFACING @ 3.5 INCH DEPTH INCLUDING REQUIRED TURNDOWN EDGES.	2,875	FT	\$	\$
3	PROVIDE PLAYGROUND STRUCTURE PER DESCRIPTION.	1	LS	\$	\$
4	PROVIDE SWING(S) FOR TODDLERS AND CHILDREN AGES 5 TO 12 PER DESCRIPTON	1	E.A.	\$	\$
5	PROVIDE STAND ALONE SPINNER OR CLIMBING ELEMENT PER DESCRIPTION	1	E.A.	\$	\$
6	INSTALLATION OF ALL PLAYGROUND EQUIPMENT	1	LS	\$	\$
7	FORCE ACCOUNT ALLOWANCE	1	LS	10%	\$

Total Project Bid Price in Numbers (Items 1-7)

\$ \_\_\_\_\_

Total Bid in Words:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_